BOOK /83 PAGE 79/

FILED FOR REGORD SKANAME 30. WASH BY Planning Dept

DEC | JII'N

GARY M. OLSON

Return Address:

Planning Department

Please Print or Type Information.	
Document Title(s) or transactions contained therein:	
1. Site Inspection Report	
2. 3.	
4.	THE RESERVE AND ADDRESS OF THE PROPERTY OF THE
GRANTOR(S) (Last name, first, then first name and initials)	,
1. Braun Intertec Corporation 2.	
3.	1
Additional Names on page of document.	~ \
GRANTEE(S) (Last name, first, then first name and initials)	•
1. Alpine Quality Construction 2. Meadow Short Plat 3. 4. [] Additional Names on page of document	62
LEGAL DESCRIPTION (Abbreviated: I.E., Lot, Block, Plat or Section, To .iship	, Range, Quarter/Quarter) .
SE4 Section 25, T3N R7EMM	
[] Complete legal on page of document.	
REFERENCE NUMBER(S) Of Documents assigned or released: Vol. 3 Pg 34 of Short Plats	W 1 (the strength and the
[] Additional numbers on page of document.	259.400.00 240.00
ASSESSOR'S PROPERTY TAX PARCEL/ACCOUNT NUMBER 03-07-25-4-0-0200-00 [] Property Tax Parcel ID is not yet assigned.	H (FINE)
[] Additional parcel #'s on page of document.	New Private Contracting
The Auditor/Recorder will rely on the information provided on the form	n. The Staff will not read



Braun Interfec Corporation 6032 N Culter Circle, Ste. 480 P.O. Box 17126 Partitional Cregon 97217 507 289 1778 Fax: 289.1918

February 20, 1997 Revised August 17, 1998 Revised August 31, 1998 Engineers and Scientists Servina
the Built and Natural Environments

Project No. EAAX-97-0158

Report No. 09-027-2760

Mr. Terry Ryan Alpine Quality Construction Services 16505 S.E. 1st Street Vancouver, Washington 98684

Dear Mr. Ryan:

Re: Preliminary Site Stability Evaluation Report
Meadow Short Plat, Baker Road, Stevenson, Washington

In 1997, Braun Intertee Corporation conducted a site reconnaissance of the referenced site to evaluate site stability and landslide hazards. Authorization for our initial services was provided by Mr. Terry Ryan on February 6, 1997. This report represents a revision to the initial February 20, 1997, report based upon division of the property into short plats and modifications suggested by county official feedback, and recent site visits on July 28 and August 13, 1998, Please refer to previous reports (09-027-2760 dated February 20, 1997, and 09-107-3337 dated October 6, 1997).

Project Description

The site is located roughly a mile north of the City of Stevenson, near Baker Road, as shown in an attached Site Location Map, Figure 1. It is situated in a portion of the SE 1/4 of Section 25, T3N, R7E, W.M. Skamania County, Washington.

We understand that present plans are to develop the site into several individual lots as shown in an acched Lot-Layout Plan, Figure 2, prepared by Lawson Surveying and Engineering.

Alpine Quality Construction Project No. EAAX-97-0158 Report No. 09-02-2760 February 20. 1997 Revised August 17, 1998 Revised August 31, 1998 Page 2

Purpose and Scope

The purpose of our evaluation was to visually assess the surface soil conditions at the site in order to preliminarily evaluate the site stability and landslide hazards. In general, our scope of work included following specific items:

- Site visits to observe surface conditions at the site and in the site violaity to evaluate site stability.
- Historical research including aerial photographs and USGS maps.
- Geological and USDA literature review, including the evaluation of available geological hazard maps
- Review of available city and county records on the site development activities.
- Computer modelling using XSTABL software and engineering analyses to evaluate existing site stability.
- Preparation of this report.

Site Description

The short plat is part of an undeveloped parcel of land located west of Kanaka Cre & Road. As shown in attached Figure 1. Baker Road runs east-west just to the south of the site. The site is bounded to the north by an airstrip and a plateau, and to the west by another short plat, to the east by undeveloped private property, and to the south by other portions of the undeveloped 25-acre parcel.

Surface Features

At present, the area is densely wooded in the northernmost portions of the site. The remaining portion of the site is generally cleared.

The topography of the site and surrounding area generally consists of a northern plateau near Ei. 900 which trends gently downslope to a steeper slope (50 to 60 feet at 0.5H:1V) just north of

Alpine Quality Construction Project No. EAAX-97-0158 Report No. 09-02-2760 February 20, 1997 Revised August 17. 1998 Revised August 2. 48 Page 3

Baker Road. South of Baker Road, the site topography is rolling and gently sloping downwards to the south.

Site Specific Stability Observations

At the time of our 1997 site visit, we noted evidence of erosion from surface water run-off over the steep cleared slope just north of Baker food. We noted minor surface drainage generally running from the northern elevated areas to the southern low lying area. In general, we did not notice unusual surface water features such as filled depressions, de p creeks, disarranged drainage systems, etc which are sometimes indicative of previous landslide activities or slope instability.

During our 1997 and more recent site visits, we did not notice scarps, crevices and depressions, tension cracks in the ground surface, severely bent tree bottoms, tilted trees, irregular toes, exposed surfaces of ruptures without vegetation, presence of distinct feet growing vegetation, undrained depressions, on that are generally indicative of active and/or inactive landslides or slope instability.

Site Vicinity Observations

Our site reconnaissance did not indicate visual evidence of slope instability or landslide hazards in areas a ligation to the site boundaries at the time of our site visits.

Based on our interviews with the City of Stevenson officials, we believe, an unstable area exists west of Kanaka Creek Road. This unstable area is located at least one-half mile from the site. There is no vignal evidence of this unstable area affecting the site stability. The site is located sufficiently away from the toe of the unstable area. If a major landslide occurs in this unstable area, it is not anticipated to impact the site because of a great distance and the presence of roadways between these two areas. Moreover, the unstable area is being evaluated and mitigated by the city of Steverson.

Soils and Geology

During our 1997 site visit, we observed 5-foot to 6-foot high cut slopes along Baker Road, and cleared face of a 50 to 60 foot tall steep slope situater just north of Bøker Road. Observations of August 13, 1998, were made of the utility trench along the newly graded roadway which traverses the 50-s. Based on these observations, our knowledge of the site, and our evaluation of in-house data from other projects, in our opinion, the site is generally underlain by medium

Alpine Quality Construction Project No. EAAX-97-0158 Report No. 09-02-2760 February 20. 1997 Revised August 17, 1998 Revised August 31, 1998 Page 4

dense to dense or stiff mixtures of clays, silts, and fine grained sands, and some cobbles (SM/ML). These soils are generally poorly drained. Based on our geologic literature review, we believe these soils extend to several tens of feet in depth. These soils generally represent completely weathered volcanoclastic rocks and conglomerates that were made of volcanic debris flow, mud flow, and fluvial n vorking of volcanic deposits.

Groundwater

As mentioned earlier, we noted evidence of erosion from surface water run-off over the steep cleared slope just north of Baker Road south of the subject site. We noted minor surface water drainages generally running from the northern elevated areas to the southern low lying area south of Baker Road.

We believe, due to a thick vegetation cover and root system of dense woods on the northernmost area of the site, rainfall over this area is draining surficially to the touth. Some infilination is anticipated to occur over the steep cleared slopes near Baker Road. Due to poorly drained characteristics of soils, surface water run-off continues to flow toward the south in minor natural surficial draininges.

The presence of surface water run-off is an indication of a potential for perched groundwater conditions at the site. Based on our knowledge of the site, we believe the actual groundwater table is fairly deep. The perched groundwater may exist within upper 3 to 5 feet and flows laterally downwards towards the south.

Slope Stability Evaluation

Using the soils/geology and groundwater data mentioned above, in 1997 we performed preliminary site slope stability analyses. We used a computer modelling software (XSTABL) to model on-site slopes. Specifically, we chose conservative soil strength parameters based on the results of our field and research activities. Our results of preliminary slope stability analyses indicated that, at this time, the site is stable from slope instability or landslide hazards perspective.

Alpine Quality Construction Project No. EAAX-97-0158 Report No. 09-02-2760 February 20, 1997 Revised August 17, 1998 Revised August 31, 1998 Page 5

Conclusions and Recommendations

Based on the results of our field work and engineering analysis, it is our opinion that the site is suitable for the proposed development provided the following general recommendations are incorporated into future design and construction activities at the site.

We recommend that the individual lots be specifically evaluated by a geotechnical engineer after the proposed house construction plans are available. In general, the following issues must be addressed prior to the construction of residencial structures on individual lots at the site.

- Stability of any access road embankments or curs;
- Stability of any cut slopes and fill slopes to achieve finished floor grade;
- Retaining wall requirements and design;
- Foundation drains and surface drains;
- Subsurface exploration which may consist of test pits, soil borings, or inspection of the
 excavarions for footings to prepare geotechnical recommendations for site preparation
 and foundation support.

General

This report should not be used for actual construction of structures on the site. We should be contacted to provide geotechnical recommendation once the construction and site development pions are finalized. The conclusions and recommendations presented in this report are subject to the following general conditions.

Alpine Quality Construction Project No. EAAX-97-0158 Report No. 09-02-2760 February 20, 1997 Revised August 17, 1998 Revised August 31, 1998 Page 6

We understand that this report will be filed with Skamania County, Washington. This repo. as been prepared for the exclusive use of the addressne and their representative to use to design the proposed structure described herein and prepare construction documents. However, we understand that the information contained herein may be of interest to other parties. The data, analyses and recommendations may not be appropriate for other structures or purposes. We recommend that parties contemplating other structures or purposes contact us. In the absence of our written approval, we make no representation and assume no responsibility to other parties regarding this report.

Services performed by the geotechnical and materials engineer for this project have been conducted with that level of care and skill ordinarily exercised by members of the profession currently practicing in this area under similar budget and time restraints. No warranty, expressed or implied, is made.

We appreciate the opportunity to be of service to you at this time. We will be pleased to provide additional assistance or information at your request. Please call us at (800)-783-6985 if you have any questions regarding this report.

Sincerely,

William M. Weyrauch, PE

'Vice President / Principal Engineer

Attachments - Site Location Map, Figure 1 Lot Layout Plan - Figure 2

: Braun Intertec Corporation, St. Cloud

f:/groups/eaax/geotech/a-m/eaax97m1.158



