

SCHEDULE "A" - DESCRIPTION OF EQUIPMENT
(continued)

41-1-64

Item No.	Unit No.	Type and Description
11	11	Air Compressor

One (1) Model PB8 Chicago-Pneumatic 8 3/8 - 4 3/4x5" simple valve air compressor #53844, 8 cylinder V-type 2-stage compressor with radiator type inter-cooler, intake filters, extended structural base and V-belt drive by 100 H.P., 1200 R.P.M., 440 V, Allis-Chalmers ball bearing induction motor #23DB-51-645-659-59.

One (1) Manual motor starting compensator and 2"x25' conduit wiring with flexible connection.

One (1) Size L2100 Chicago-Pneumatic aftercooler with flanged separator water piping connections.

One (1) 30" Diameter by 6' high welded steel air receiver, with trimmings.

One (1) Air piping system with 2" main from receiver and lines to feed plant units.

12	12	Air Compressor
----	----	----------------

One (1) 1 1/2 H.P. Horizontal tank mounted air compressor unit with single phase motor, model A320 vertical compressor #B-129557, trimmings and connections.

13	13	Power Wiring
----	----	--------------

Panel Noar Lathes

One (1) 600 Amp., 600 V. 3-pole safety switch.

One (1) 400 Amp., 600 V., 3-pole safety switch.

One (1) 200 Amp., 600 V., 3-pole safety switch.

Four (4) 100 Amp., 600 V., 3-pole safety switches.

Five (5) 60 Amp., 600 V., 3-pole safety switches.

Five (5) 30 Amp., 600 V., 3-pole safety switches.

One (1) 6x18" - 16' Steel bus gutter.

Two (2) Lead-ins to panel with 6' - 3" conduit wiring, 1 factory elbow and 1 entrance conduit, open wiring to transformer setting adjoining.

One (1) 25 KVA single phase air-cooled lighting transformer.

Note: Starters included with motors.