

129330

Return Address: Bobby Durdel
P.O. Box 175
Scappoose, OR 97056

BOOK 169 PAGE 401

FILED FOR RECORD
SKAMANIA CO. WASH
BY *Bobby Durdel*

SEP 25 4 22 PM '97

Polowy
AUDITOR
GARY H. OLSON

Skamania County
Department of Planning and
Community Development

Skamania County Courthouse Annex
Post Office Box 790
Stevenson, Washington 98648
509 427-9458 FAX 509 427-4839

Director's Decision

APPLICANT: Bobby Durdel

FILE NO.: NSA-97-06

PROJECT: Single-family residence with attached garage, deck and accessory building

LOCATION: Approximately milepost 33.75 of SR-14, in Skamania, Section 35 of T2N, R6E, W.M. and identified as Skamania County Tax Lot # 2-6-35-1100.

ZONING: Commercial Forest (F-1) and Residential (R-5).

DECISION: Based upon the entire record before the Director, including particularly the Staff Report, the application by Bobby Durdel, described above, subject to the conditions set forth in this Decision, is found to be consistent with Title 22 SCC and is hereby approved with the exception of the accessory building which is **DENIED**.

Although the proposed development is approved, it may not be buildable due to inadequate soils for septic and/or lack of potable water. These issues are under the jurisdiction of Skamania County's Building Department and the Washington State Health District.

Approved
Reviewed, Dir. ☒
Indirect ☒
Filed ☒
Noted ☒

Skamania County Planning and Community Development
File: NSA-97-06 (Durdell) Director's Decision
Page 2

Approval of this request does not exempt the applicant or successors in interest from compliance with all other applicable local, state, and federal laws.

CONDITIONS OF APPROVAL:

The following conditions are required to ensure that the subject request is consistent with Skamania County Title 22. This document, outlining the conditions of approval, must be recorded in the deed records of the Skamania County Auditor in order to ensure notice of the conditions of approval to successors in interest. SCC §22.06.050(C)(2).

- 1) All developments shall be consistent with the enclosed site plan, unless modified by the following conditions of approval. If modified, the site plan shall be consistent with the conditions of approval.
- 2) All buildings shall be surrounded by a maintained fuel break of 50 feet. Irrigated or fire resistant vegetation may be planted within the fuel break, including green lawns and low shrubs (less than 24 inches in height). Trees should be placed greater than 15 feet between the crown and pruned to remove dead and low (less than 8 feet) branches. Accumulated leaves, needles and other dead vegetation shall be removed from beneath trees.
- 3) Hazardous fuels shall be removed within the fuel break area.
- 4) Buildings with plumbed water systems shall install at least one standpipe at a minimum of 50 feet from the structure(s).
- 5) A pond, stream, tank or sump with storage of not less than 1,000 gallons, or a well or water system capable of delivering 20 gallons per minute shall be provided. If a well pump is located on-site, the electrical service shall be separate from the dwelling.
- 6) Access drives shall be constructed to a minimum of 12 feet in width and not exceed a grade of 12 percent. Turnouts shall be provided at a minimum of every 500 feet. Access drives shall be maintained to a level that is passable to fire equipment.
- 7) Within one year of the occupancy of a dwelling, the Department shall conduct a review of the development to assure compliance with these this section.
- 8) Telephone and power supply shall be underground.
- 9) Roofs of structures should be made of fire-resistant materials, such as metal, fiberglass shingle or tile. Roof materials such as cedar shake and shingle should not be used.

Skamania County Planning and Community Development
File: NSA-97-06 (Durdell) Director's Decision
Page 3

- 10) Any chimney or stovepipe on any structure for use with a woodstove or fireplace should be screened with no coarser than 1/4 inch mesh metal screen that is noncombustible and corrosion resistant and should be equipped with a spark arrestor.
- 11) All structural projections such as balconies, decks and roof gables should be built with fire resistant materials equivalent to that specified in the Uniform Building code.
- 12) Attic openings, soffit vents, foundation louvers or other ventilation openings on dwellings and accessory structures should be screened with no coarser than 1/4 inch mesh metal screen that is noncombustible and corrosion resistant.
- 13) Front yard setbacks shall be 15 feet from the front lot line or forty-five feet from the centerline of a public or private road. Side yard setbacks shall be five feet and rear yard setbacks shall be fifteen feet.
- 14) A variance shall be granted to allow the residence to be less than 100 feet from Highway 14. The setbacks required in Condition #13 shall apply.
- 15) The exteriors of the proposed buildings shall be composed of nonreflective materials or materials with low reflectivity. Prior to issuance of a building permit, applicant shall be required to submit color samples to provide compliance with above criteria.
- 16) Exterior lighting shall be directed downward and sited, hooded and shielded such that it is not highly visible from key viewing areas. Shielding and hooding materials shall be composed of nonreflective, opaque materials. All lights shall be hooded and shielded so as to have a luminary with less than a 90 degree cutoff.
- 17) If more than 100 cubic yards of grading will occur, than a grading plan shall be submitted prior to issuance of a building permit.
- 18) Applicant shall be required to retain existing tree cover screening the development from key viewing areas except that which is necessary for site development.
- 19) The accessory building shall not be allowed within 100 feet of SR-14. Since the subject property is only 90 feet wide it would be impossible to locate the accessory building on the property and be in compliance with the ordinance, as no variances are allowed for accessory buildings. Therefore the request for the accessory building shall be **DENIED**.
- 20) A continuous row of trees, six feet tall at the time of planting, 12 feet on center, shall be planted north and south of the proposed residence to screen development from SR-14 and the Columbia River. At least half of any trees planted for screening purposes shall be native to the setting and half shall be coniferous to provide winter screening. Arborvitae are not considered native.

Skamania County Planning and Community Development
File: NSA-97-06 (Durdell) Director's Decision
Page 4

- 21) Applicant shall be required to achieve visual subordination prior to issuance of an occupancy permit.
- 22) The following procedures shall be effected when cultural resources are discovered during construction activities:
 - a) Halt Construction. All construction activities within 100 feet of the discovered cultural resource shall cease. The cultural resources shall remain as found; further disturbance is prohibited.
 - b) Notification. The project applicant shall notify the Planning Department and the Gorge Commission within 24 hours of the discovery. If the cultural resources are prehistoric or otherwise associated with Native Americans, the project applicant shall also notify the Indian tribal governments within 24 hours.
 - c) Survey and Evaluations. The Gorge Commission shall arrange for the cultural resources survey.

Dated and Signed this 23rd day of June, 1997, at Stevenson, Washington.


Harpreet Sandhu, Director
Skamania County Planning and Community Development.

NOTES

Any new residential development, related accessory structures such as garages or workshops, and additions or alterations not included in this approved site plan, will require a new application and review.

As per SCC §22.06.050(C)(2), the Director's Decision shall be recorded in the County deed records prior to commencement of the approved project.

As per SCC §22.06.050(C)(5), the decision of the Director approving a proposed development action shall become void in two years if the development is not commenced within that period, or when the development action is discontinued for any reason for one continuous year or more.

APPEALS

The decision of the Director shall be final unless a written Notice of Appeal is filed by an interested person within 20 days from the date hereof. Appeal may be made to the Skamania County Board of

BOOK 169 PAGE 405

Skamania County Planning and Community Development
File: NSA-97-06 (Durdell) Director's Decision
Page 5

Adjustment, P.O. Box 790, Stevenson, WA 98648, on or before 7-14-97. Notice of Appeal forms are available at the Department Office.

A copy of the Decision was sent to the following:

Skamania County Building Department
Skamania County Assessor's Office

A copy of this Decision, including the Staff Report, was sent to the following:

Persons submitting written comments in a timely manner
Yakama Indian Nation
Confederated Tribes of the Umatilla Indian Reservation
Confederated Tribes of the Warm Springs
Nez Perce Tribe
Columbia River Gorge Commission
U.S. Forest Service - NSA Office
Board of County Commissioners

<nsa-durdell.dd>

