

Return Address: Donald and Carolyn Schut
220 S Kershaw Drive
Yakima, WA, 98908

**Skamania County
Department of Planning and
Community Development**

Skamania County Courthouse Annex
Post Office Box 790
Stevenson, Washington 98648
509 427-9458 FAX 509 427-8288

Administrative Decision

APPLICANT/OWNER: Don and Carolyn Schut

FILE NO.: NSA-04-43

PROJECT: Single-family dwelling (1,344 Square footprint) extend driveway, and associated utilities.

LOCATION: 1.57 acres at along Hood Road in Underwood, WA; Section 22 of Township 3N, Range 10E, W.M. and identified as Skamania County Tax Lot #03-10-22-0-0-1302-00.

LEGAL: Lot 3 of Sroufe Short Plat recorded @ book 2, page 96.

ZONING: General Management Area zoned Residential (R-5).

DECISION: Based upon the record and the Staff Report, the application by Don and Carolyn Schut, described above, **subject to the conditions set forth in this Decision**, is found to be consistent with Title 22 SCC and is hereby approved.

Although the proposed development is approved, it may not be buildable due to inadequate soils for septic and/or lack of potable water. These issues are under the jurisdiction of Skamania County's Building Department and the Skamania County Health Department.

Approval of this request does not exempt the applicant or successors in interest from compliance with all other applicable local, state, and federal laws.

CONDITIONS OF APPROVAL:

The following conditions are required to ensure that the subject request is consistent with Skamania County Title 22. This document, outlining the conditions of approval, must be recorded by the applicant in

COPY

Skamania County Planning and Community Development
File: NSA-04-43 Administrative Decision
Page 2

the deed records of the Skamania County Auditor in order to ensure notice of the conditions of approval to successors in interest. SCC §22.06.050(C)(2).


- 1) As per SCC §22.06.050(C)(2), this Administrative Decision **SHALL BE RECORDED** by the applicant in the County deed records prior to commencement of the approved project. A copy of the first page of the recorded Administrative Decision must be submitted to the Planning Department prior to issuance of a building permit.
 - 2) All developments shall be consistent with the enclosed site plan, unless modified by the following conditions of approval. If modified, the site plan shall be consistent with the conditions of approval.
 - 3) Setbacks (including roof/ eaves, decks/ porches and overhangs) for all structures shall be as follows: **Front yard:** 45 feet from the centerline of the street or road or 15 feet from the front property line, whichever is greater, **Side yard:** 5 feet, **Rear yard:** 15 feet. Determination of the property line location is the responsibility of the applicant and must be confirmed by a surveyor if the property boundary is in question.
 - 4) The development shall comply with the following fire safety guidelines (a)-(k);
 - a) All buildings shall be surrounded by a maintained fuel break of 50 feet. Irrigated or fire resistant vegetation may be planted within the fuel break, including green lawns and low shrubs (less than 24 inches in height). Trees should be placed greater than 15 feet between the crown and pruned to remove dead and low (less than 8 feet) branches. Accumulated leaves, needles and other dead vegetation shall be removed from beneath trees.
 - b) Hazardous fuels shall be removed within the fuel break area.
 - c) Buildings with plumbed water systems shall install at least one standpipe at a minimum of 50 feet from the structure(s).
 - d) A pond, stream, tank or sump with storage of not less than 1,000 gallons, or a well or water system capable of delivering 20 gallons per minute shall be provided. If a well pump is located on-site, the electrical service shall be separate from the dwelling.
 - e) Access drives shall be constructed to a minimum of 12 feet in width and not exceed a grade of 12 percent. Turnouts shall be provided at a minimum of every 500 feet. Access drives shall be maintained to a level that is passable to fire equipment.
 - f) Within one year of the occupancy of a dwelling, the Department shall conduct a review of the development to assure compliance with these this section.
 - g) Telephone and power supply shall be underground whenever possible.
-

- h) Roofs of structures should be made of fire-resistant materials, such as, fiberglass shingle or tile. Roof materials such as cedar shake and shingle should not be used.
 - i) Any chimney or stovepipe on any structure for use with a wood stove or fireplace should be screened with no coarser than 1/4 inch mesh metal screen that is noncombustible and corrosion resistant and should be equipped with a spark arrestor.
 - j) All structural projections such as balconies, decks and roof gables should be built with fire resistant materials equivalent to that specified in the Uniform Building code.
 - k) Attic openings, soffit vents, foundation louvers or other ventilation openings on dwellings and accessory structures should be screened with no coarser than 1/4 inch mesh metal screen that is noncombustible and corrosion resistant.
- 5) Only the grading which is necessary for site development (building pads, driveway and utilities) is permitted.
- 6) The existing tree cover shall be retained as much as possible, except as is necessary for site development (i.e. building pads, drain field, access roads), safety purposes, or forest management practices or fire safety guidelines.
- 7) Due to sensitive wildlife habitat, no exterior construction shall occur between March 1st and August 31st.
- 8) The applicant shall comply with all conditions for visual subordination, prior to final inspection by the Building Department. The applicant shall coordinate all inspections with the Building Department. Planning Department staff should be able to conduct a final inspection site visit within four business days from the time of calling for the inspection. Final inspection and an occupancy permit will not be issued until compliance with all conditions of approval, including visual subordination criteria, has been verified.
- 9) The Planning Department will conduct at least two site visits during construction. Each inspection may take up to four business days from the time of calling for the inspection. Inspections should be arranged by calling the Building Department at 509-427-9484.
- 10) The following procedures shall be effected when cultural resources are discovered during construction activities:
- a) Halt Construction. All construction activities within 100 feet of the discovered cultural resource shall cease. The cultural resources shall remain as found; further disturbance is prohibited.
 - b) Notification. The project applicant shall notify the Planning Department and the Gorge Commission within 24 hours of the discovery. If the cultural resources are prehistoric or otherwise associated with Native Americans, the project applicant shall also notify the Indian tribal governments within 24 hours.
-

Skamania County Planning and Community Development
File: NSA-04-43 Administrative Decision
Page 4

- c) Survey and Evaluations. The Gorge Commission shall arrange for the cultural resources survey.

Dated and Signed this 23 day of Sept., 2004, at Stevenson, Washington.


Patrick Johnson, Associate Planner
Skamania County Planning and Community Development.

NOTES

Any new residential development, related accessory structures such as garages or workshops, and additions or alterations not included in this approved site plan, will require a new application and review.

As per SCC §22.06.050(C)(5), this Administrative Decision approving a proposed development action shall become void in two years if the development is not commenced within that period, or when the development action is discontinued for any reason for one continuous year or more.

APPEALS

The Director reserves the right to provide additional comment and findings of fact regarding this decision, if appealed.

This Administrative Decision shall be final unless reversed or modified on appeal. A written Notice of Appeal form must be filed by an interested person within 20 days from the date hereof. Appeals are to be made to the Skamania County Board of Adjustment, P.O. Box 790, Stevenson, WA 98648. Notice of Appeal forms are available at the Planning Department Office and must be accompanied by a \$500.00 nonrefundable filing fee.

WARNING

On November 30, 1998 the Columbia River Gorge Commission overturned a Skamania County Director's Decision 18 months after the 20-day appeal period had expired. You are hereby warned that you are proceeding at your own risk and Skamania County will not be liable for any damages you incur in reliance upon your Administrative Decision or any amendments thereto.

A copy of the Decision was sent to the following:

Skamania County Planning and Community Development
File: NSA-04-43 Administrative Decision
Page 5

Skamania County Health Dept.
Skamania County Building Department
Skamania County Assessor's Office

A copy of this Decision, including the Staff Report, was sent to the following:

Persons submitting written comments in a timely manner
Yakama Indian Nation
Confederated Tribes of the Umatilla Indian Reservation
Confederated Tribes of the Warm Springs
Nez Perce Tribe
Office of Archaeology and Historic Preservation
Columbia River Gorge Commission
U.S. Forest Service - NSA Office
Board of County Commissioners
Dee Caputo, CTED

Unofficial
Copy

